

STANDARD FOR UNDERGROUND METER INSTALLATIONS

NO METER
INSTALLATIONS
ON BUILDINGS

**SWCE reserves the right
to refuse to terminate and
energize any substandard
meter sites**

**Steele-Waseca Cooperative
Electric: 800-526-3514**

Conduit, Wires, Meter Socket
and Service Disconnect
Means to be supplied and
installed by Member or an
Electrical Contractor

6 x 6 Treated Post
Single or Double Post
May be a substantial steel
structure. Provided and
installed by member or
electrical contractor.

