

STANDARD FOR UNDERGROUND METER INSTALLATIONS

NO METER INSTALLATIONS ON BUILDINGS

SWCE reserves the right to refuse to terminate and energize any substandard meter sites

Conduit, Wires, Meter Socket and Service Disconnect Means to be supplied and installed by Member or an Electrical Contractor

Steele-Waseca Cooperative Electric: 800-526-3514

6" x 6" Treated Post
Single or Double Post
May be a substantial steel structure. Provided and installed by member or electrical contractor.

